



THE NEW YORK BLOWER COMPANY
7660 Quincy Street
Willowbrook, IL 60527-5530

Visit us on the Web: <http://www.nyb.com>
Phone: (800) 208-7918 Email: nyb@nyb.com

GUIDE SPEC
GS-591
June 2007

SPECIFYING FRP FAN EQUIPMENT FPB FANS

GENERAL

The fans shall be size _____ single-width single-inlet as designed and manufactured by The New York Blower Company. The fan shall be constructed such that all surfaces in contact with the corrosive gas stream are to be made of corrosion-resistant FRP. All nuts, bolts and fasteners in contact with the gas stream shall be type 316 SST and encapsulated in FRP. Fans shall be AMCA Arrangement 1, 8 or 10. AMCA Arrangement 4, which places the motor shaft in the corrosive gas stream, is unacceptable.

PERFORMANCE

Fan ratings shall be based on tests made in accordance with AMCA Standard 210 in an accredited AMCA laboratory. Fans shall offer stable performance to closed off damper position. Fan brake horsepower shall be equal to or less than _____ BHP at _____ inches static pressure and _____ CFM at _____ density.

SOUND

Fan manufacturers shall provide sound power level ratings for fans tested and rated in accordance with AMCA Standards 300 and 301. Tests shall be performed in an accredited AMCA laboratory. Sound power ratings shall be in decibels (reference 10-12 watts) in eight octave bands. Sound power levels will be corrected for installation by the specifying engineer...dBA levels only are not acceptable.

BEARINGS

Bearings are to be grease lubricated, precision anti-friction ball, pillow block design. Bearings shall be designed for a minimum L-10 life of 30,000 hours (150,000 hours L-50 life) when rated at the fan's maximum cataloged operating speed. Fan bearings shall be visible and accessible for inspection and maintenance. Bearings enclosed within the fan housing where they can be exposed to the corrosive gas stream are not acceptable.

CORROSION PROTECTION OF STEEL/FINISH COATING

All steel fan surfaces are to be thoroughly cleaned prior to painting using a combination of washing and hand/power tool cleaning per SSPC-SP1, SSPC-SP2 and SSPC-SP3 standards. (Option: all steel fan surfaces are to receive as a minimum, cleaning per SSPC-SP6 std.) After cleaning, all fan exterior surfaces are to receive a coat of manufacturer's standard primer followed by one coat of epoxy enamel finish to a thickness of 2-3 mils d.f.t. Surfaces of bolted components shall be coated and allowed to dry prior to final assembly. All fasteners external to the gas stream shall be plated for extra corrosion protection.

CONSTRUCTION

Fan shall be constructed in accordance with the ASTM D-4167 standard specification for fiber-reinforced plastic fans and blowers to ensure structural integrity. All parts exposed to the gas stream shall be constructed of, or encapsulated in, an FRP laminate capable of resisting continuous airstream temperatures of 250°F.

All resins shall be clear to allow detection of subsurface imperfections. Use of pigments, gel coats, inhibitors and additives which may disguise flaws in the laminate is prohibited.

Other minimum construction requirements shall consist of the following:

I. Housing - Fan housing shall be constructed of a fire-retardant vinyl ester resin with an ASTM E84 Class I rating. Housing laminate construction shall conform to ASTM Standard C-582.

Airstream surfaces shall be smooth to minimize resistance and prevent build-up of airborne contaminants. Fan shall be furnished with flanged inlet and outlet. (Option: flanges are to be drilled to PS 15-69 or ANSI Class 150.)

Shaft hole opening in the housing drive side shall be designed to minimize leakage. (Option: fan shall be furnished with a lubricatable, double-lip, Teflon® or Viton® shaft seal.)

- II. **Wheel** - Wheel shall be of radial bladed design for stable pressure development. Wheel shall be cast from a solid resin-glass mixture and oven cured to provide optimum strength and corrosion resistance. Resin used in the construction of wheels shall be a fire retardant vinyl ester with an ASTM E84 Class II rating no greater than 30. Wheel is to be permanently bonded to the shaft to ensure corrosion-resistant integrity. Wheels with taper-lock hubs are not acceptable.
- III. **Shaft** - Shaft shall be ASTM A-108 steel, grade 1040/1045 with an FRP sleeve fixed securely and bonded to the wheel backplate. The sleeve shall extend out through the housing shaft hole for corrosion protection. (Option: Shaft or shaft sleeve shall be 316 SST or Hastelloy® C-276.) The shaft first critical speed shall be at least 125% of the fan's maximum operating speed. Shaft shall be countersunk for tachometer readings.

BALANCE AND RUN TEST

The wheel and shaft shall be dynamically balanced as an assembly, and the fan will be balanced in accordance with the limits set forth in AMCA 204, Section 6, Table 6-3 for Industrial Process and Power Generation Equipment level BV-3 (.15 in/sec. filter-in at both bearings in the horizontal and vertical planes).

WARRANTY

Fan manufacturer shall warrant that all fan components shall be free from defects in materials and workmanship for a period of one (1) year after shipment from its plant.

ACCESSORIES

Accessories shall be provided as called for in the plans and specifications. Required accessories include:

- Companion Flange
- Flange Drilling
- Shaft Seal - Viton, Teflon
- Wafer-Type Outlet Damper
- Surface Veil
- Graphite Impregnation
- All-Vinyl Ester Airstream
- Teflon Shaft Hole Closure
- Inspection Port
- Alloy Wheels
- Drain - Threaded, w/PVC Plug
- Flexible Coupling
- Weather Cover (Arr. 10)
- Positive Screw Adj. (Arr. 10)
- Safety Equipment
- Belt Guard
- Shaft Guard
- Coupling Guard
- Unitary Base
- R-I-S Isolators
- Spring Isolators
- Isolation Rails (Arr. 10)
- R-I-S Isolators
- Spring Isolators
- V-Belt Drive
- Adjustable, Constant

© Registered Trademark of The New York Blower Company
© Teflon and Viton are registered trademarks of DuPont and DuPont Dow Elastomers respectively.
Hastelloy is a registered trademark of Haynes International, Inc.