



THE NEW YORK BLOWER COMPANY
7660 Quincy Street
Willowbrook, IL 60527-5530

Visit us on the Web: <http://www.nyb.com>
Phone: (800) 208-7918 Email: nyb@nyb.com

GUIDE SPEC
GS-676
June 2007

SPECIFYING DIRECT DRIVE VANEAXIAL FANS

GENERAL

The fans shall be size _____ Vaneaxial as designed and manufactured by The New York Blower Company. Fan wheels shall utilize cast aluminum, airfoil blades in all sizes. Unless other-wise directed, fans shall be in compliance with the layout shown on the drawings.

PERFORMANCE

Fan ratings shall be based on tests made in accordance with AMCA Standard 210 and performed in an accredited AMCA laboratory. Fan brake horsepower shall be equal to or less than _____ BHP at _____ inches static pressure and _____ CFM at _____ density.

SOUND

Fan manufacturers shall provide sound power level ratings for fans tested and rated in accordance with AMCA Standards 300 and 301. Tests shall be performed in an accredited AMCA laboratory. Sound power ratings shall be in decibels (reference 10^{-12} watts) in eight octave bands. Sound power levels will be corrected for installation by the specifying engineer...dBA levels only are not acceptable.

CONSTRUCTION

Fan housings are to be heavy gauge, continuously welded construction. Housings with lock seams or partially welded construction are not acceptable. Aerodynamically designed straightening vanes are to be integral to the fan housing.

PAINT

All fan surfaces are to be thoroughly prepared prior to painting using a combination of washing and hand and power tool cleaning as required. After cleaning, all surfaces are to be coated with an industrial grade alkyd enamel. Surfaces of bolted components not accessible after assembly shall be coated and allowed to dry prior to final assembly. Primer only will not be accepted

BALANCE AND RUN TEST

All fan wheels shall be precision balanced prior to assembly. Fans complete with motors shall receive a final test balance at the specified operating speed.

ACCESSORIES

Accessories shall be provided as called for in the plans and specifications.

Standard accessories include:

- Inlet Flange
- Outlet Flange
- Vane Section

Required accessories include:

- Mounting Arrangement - Floor, Roof, Vertical, Duct, Suspended
- Access Door
- Drain
- Drain Plug
- Inlet Vane Damper
- Easy Access Construction
- Outlet Guard
- Companion Flange
- Stack Hood
- Curb Cap
- Vibration Isolation - Spring - Rubber-In-Shear
- Inlet Bell with Guard
- Silencer
- Extended Inlet Guard

FINAL INSPECTION

All fans shall receive a final inspection by a qualified inspector prior to shipment. Inspection to include: fan description and accessories, balance, welding, dimensions, bearings, duct and base connection points, paint finish and overall workmanship.

© Registered Trademark of The New York Blower Company

Form 607 GAW